



CITY OF STAYTON
MEMORANDUM

TO: Mayor Henry Porter and the Stayton City Council
FROM: Lisa Meyer, Office Specialist
DATE: March 16, 2020
SUBJECT: Public Works Monthly Operating Report- February 2020

KEY ACTIVITIES

STATUS

- **WWTP Facility** Effluent flows: 57.79 million gallons were treated during February. The highest Daily flow was 2.81 million gallons on the 1st and the lowest flow was 1.52 million gallons on the 29th. The average flow was 1.99 million gallons. Total rainfall for February was 2.45 inches. 22.81 dry tons of bio solids were produced. No bio solids were hauled off site in February.
- **WTP** Highest production day was 2,864,000 gallons on February 14th.
- **Water System** Replaced 4 water meters and 5 meter boxes. Cleaned water filter bed #2. Repaired water service at 1420 N. Third Ave.
- **Streets** Swept 52 curb miles and 10 cubic yards of material was collected. 2,720 lbs. of cold mix and 14 yards of gravel were applied to street potholes and street cutouts. Replaced one stop sign.
- **Parks** Parks Board: Total # of Volunteers = 6, Total # of hours = 34
- **Building Permits**

<u>Permit Type</u>	<u>Issued</u>	<u>SDC's Paid</u>
Residential/Commercial Structural	4	-
Mechanical	1	-
TOTAL	5	-

One (1) Residential SDC = \$11,835.00 + Storm Water SDC \$2,086.00 or \$2,992.00 + \$769.00 for Mill Creek SDC (if within Mill Creek Sewer Project Area)