



CITY OF STAYTON
M E M O R A N D U M

TO: Mayor Henry Porter and the Stayton City Council
FROM: Ian Kintz-Stormo
DATE: October 15, 2021
SUBJECT: Public Works Monthly Operating Report- September 2021

KEY ACTIVITIES

STATUS

- **WWTP Facility** Effluent flows: 34.34 million gallons were treated during September. The highest Daily flow was 1.52 million gallons on the 28th and the lowest flow was 0.92 million gallons on the 5th and 12th. The average flow was 1.14 million gallons. Total rainfall for September was 3.60 inches. 43 yards of Santiam Green bio-solids were given away in September by the middle of the month and we ran out.
- **WTP** Highest production day was 3,787,000 gallons on September 22nd.
- **Water System** Replaced 13 water meters. Replaced 1 meter box. Repaired 1 meter box. Repaired 2 water mains. Replaced 2 service lines.
- **Streets** Swept 125 curb miles and 17 cubic yards of material was collected.
- **Parks** None for September 2021.

• **Building Permits**

Permit Type	Issued	SDC's Paid
Residential New Single Family Dwelling	6	\$73,564.68
Residential Structural	5	-
Commercial Structural	5	-
TOTAL	6	\$73,564.68

Note: Typical SDC fees for one (1) Residential SDC = \$12,722.00 + Storm Water SDC \$2,242.00 or \$3,216.00 + \$827.00 for Mill Creek SDC (if within Mill Creek Sewer Project Area)

Links to current and previous years' Public Works Activities Reports Spreadsheets can be found on the Public Works home web page: http://staytonoregon.gov/page/pw_home