



**CITY OF STAYTON**  
**M E M O R A N D U M**

**TO: Mayor Brian Quigley and the Stayton City Council**  
**FROM: Barry Buchanan, Interim Public Works Director**  
**SUBJECT: Public Works Monthly Operating Report - July 2025**

---

**KEY ACTIVITIES**

**STATUS**

- **WWTP Facility:** 26.31 MG were treated during June of which 4.1 MG came from Sublimity. Max day – 0.86-mgd. 0.00 inches of rain fell in the month.
- **WTP:** 77.4-MG were produced during July 2025, of which 52.3-MG were accounted for. Inferring 32% unaccounted water. Peak day production for the month was 4.6-MG on July 22.
- **Water System:** Replaced 13 meters and 3 water service lines.
- **Streets:** 120 miles of curb sweeping. 480-lb of cold-mix placed in street repairs
- **Parks:** 1 playground equipment repaired.

Links to current and previous years' Public Works Activities Reports Spreadsheets can be found on the Public Works home web page.