



**CITY OF STAYTON**  
**M E M O R A N D U M**

**TO: Mayor Brian Quigley and the Stayton City Council**  
**FROM: Barry Buchanan, Interim Public Works Director**  
**SUBJECT: Public Works Monthly Operating Report - August 2025**

---

**KEY ACTIVITIES**

**STATUS**

- **WWTP Facility:** 27.21 MG were treated during June of which 4.18 MG came from Sublimity. Max day – 0.85-mgd. 0.56 inches of rain fell in the month.
- **WTP:** 71.9-MG were produced during Aug. 2025, of which 53.4-MG were accounted for. Inferring 26% unaccounted water. Peak day production for the month was 3.9-MG on Aug. 21.
- **Water System:** Replaced 11 meters and 1 water service lines.
- **Streets:** 115 miles of curb sweeping. 1520-lb of cold mix placed in street repairs
- **Parks:** 1 playground equipment repaired.

Links to current and previous years' Public Works Activities Reports Spreadsheets can be found on the Public Works home web page.