



CITY OF STAYTON
M E M O R A N D U M

TO: Mayor Brian Quigley and the Stayton City Council
FROM: Windy Cudd, Office Specialist
DATE: September 13, 2024
SUBJECT: Public Works Monthly Operating Report- August 2024

KEY ACTIVITIES

STATUS

- **WWTP Facility** Effluent flows: 31.76 million gallons were treated during August. The highest Daily flow was 1.23 million gallons on the 13th and 20th. The lowest flow was 0.82 million gallons on the 3rd. The average flow was 1.02 million gallons. Total rainfall for was 0.73 inches. No bio solids were hauled off site.
-
- **WTP** Highest production day was 4,111,000 gallons on August 15, 2024.
- **Water System** Replaced 14 meters. Replaced 2 meter boxes. Repaired 3 water service lines.
- **Streets** Swept 125 curb miles with 15 cubic yards of material removed from the streets. 3 yards of gravel applied to gravel roads.
- **Parks** Nothing for August 2024
- **Building Permits**

<u>Permit Type</u>	<u>Issued</u>	<u>SDC's Paid</u>
Residential New Single-Family Dwelling	0	-
Residential Structural	1	-
Commercial Structural	1	-
TOTAL	2	-

Note: Typical SDC fees for one (1) Residential SDC = \$12,722.00 + Storm Water SDC \$2,242.00 or \$3,216.00 + \$827.00 for Mill Creek SDC (if within Mill Creek Sewer Project Area)

Links to current and previous years' Public Works Activities Reports Spreadsheets can be found on the Public Works home web page: