



CITY OF STAYTON
M E M O R A N D U M

TO: Mayor Brian Quigley and the Stayton City Council
FROM: Windy Cudd, Office Specialist
DATE: August 15, 2024
SUBJECT: Public Works Monthly Operating Report- July 2024

KEY ACTIVITIES

STATUS

- **WWTP Facility** Effluent flows: 32.72 million gallons were treated during July. The highest Daily flow was .99 million gallons on the 29th and the lowest flow was 0.83 million gallons on the 6th. The average flow was 0.88 million gallons. Total rainfall for July was .29 inches. No bio solids were hauled off site.
- **WTP** Highest production day was 3,735,000 gallons on July 09, 2024.
- **Water System** Replaced 13 meters. Replaced 2 meter boxes. Replaced 9 water service lines.
- **Streets** Swept 120 curb miles with 14 cubic yards of material removed from the streets. 3 yards of gravel applied to gravel roads.
- **Parks** Nothing for July 2024
- **Building Permits**

<u>Permit Type</u>	<u>Issued</u>	<u>SDC's Paid</u>
Residential New Single-Family Dwelling	0	-
Residential Structural	0	-
Commercial Structural	0	-
TOTAL	0	-

Note: Typical SDC fees for one (1) Residential SDC = \$12,722.00 + Storm Water SDC \$2,242.00 or \$3,216.00 + \$827.00 for Mill Creek SDC (if within Mill Creek Sewer Project Area)

Links to current and previous years' Public Works Activities Reports Spreadsheets can be found on the Public Works home web page: