



CITY OF STAYTON
M E M O R A N D U M

TO: Mayor Brian Quigley and the Stayton City Council
FROM: Barry Buchanan, Interim Public Works Director
SUBJECT: Public Works Monthly Operating Report - September 2025

KEY ACTIVITIES

STATUS

- **WWTP Facility:** 23.35 MG were treated during Sept of which 4.38 MG came from Sublimity. Max day – 0.92-mgd. 0.97 inches of rain fell in the month.
- **WTP:** 51.4-MG were produced during Sept. 2025, of which 44.3-MG were accounted for. Inferring 13.8% unaccounted water. Peak day production for the month was 5.8-MG on Sept. 3.
- **Water System:** Replaced 2 meters and 0 water service lines.
- **Streets:** 115 miles of curb sweeping. 0-lb of cold mix placed in street repairs
- **Parks:** 1 playground equipment repaired.

Links to current and previous years' Public Works Activities Reports Spreadsheets can be found on the Public Works home web page.