

Fire Flow Calculations
 23-231 Stayton Vet Hospital
 Designer: ATR
 Date: 4/2/2024

Fire Flow Calculation Area, per building:

Building #	Fire Flow Calculation Area	Construction Type	Occupancy Type	Fire Flow ¹	Sprinklered ²	Required Fire Flow ³	Number of Hydrants Req'd ⁴
	sf			gpm		gpm	
-	-	-	-	-	-	-	-
1	11488	V-B	B	3000	No	3000	3

¹ Per 2022 OFC Table B105.1(2)

² Per IFC 903.3.1.1 and 903.3.1.2

³ Per 2022 OFC Table B105.2

⁴ Per 2022 OFC Table C102.1